



0692



GASTEC at CRE LIMITED

P.O. Box 279
Cheltenham
Gloucestershire GL52 7ZJ
United Kingdom
Tel: 01242 - 677 877
Fax: 01242 - 676 506
E-mail: gastec@cregroup.co.uk

BOILER TEST CERTIFICATE

Certificate No.: 8362
Issue Date: 11-June-03

Copy No.: 01
Test Date: June 2003

Test Fuel	Original Boiler Name	UK Market Name	Full Load Efficiency (%, net)	Part Load Efficiency (%, net)
Oil	NA	Vortex 36	101.5	106.0

Manufacturer's Name and Address:-

Grant Engineering, Crinkle Birr, County Offaly, Republic of Ireland.

We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive have been satisfied in obtaining these results.

Signed on behalf of Gastec at CRE Ltd.:

Date: 16th June 03

Print Name: Ken Porter

Position: Testing Services Manager