



0692



# BOILER TEST CERTIFICATE

Certificate No.: 8384  
Issue Date: 17 - Feb - 04

Copy No.: 01  
Test Date: Jan - Feb 2004

**GASTEC at CRE LIMITED**  
P.O. Box 279  
Cheltenham  
Gloucestershire GL52 7ZJ  
United Kingdom  
Tel: 01242 - 677 877  
Fax: 01242 - 676 506  
E-mail: gastec@cregroup.co.uk

Test Fuel	Original Boiler Name	UK Market Name	Full Load Efficiency (%, net)	Part Load Efficiency (%, net)
Oil	N A	Vortex 46	96.9	100.8

## Manufacturer's Name and Address:-

Grant Engineering, Crinkle, Birr, County Offaly, Republic of Ireland.

*We declare that the full and part load efficiency test results detailed above have been obtained by means deemed to satisfy the Boiler Efficiency Directive (92/42/EEC). The water temperature criteria defined in the Boiler Efficiency Directive have been satisfied in obtaining these results.*

Signed on behalf of Gastec at CRE Ltd.: 

Date: 18th February 2004

Print Name: Ken Porter

Position: Testing Services Manager