

Product fiche concerning the COMMISSION DELEGATED REGULATIONS

(EU)No 811/2013 of 18 February 2013

(EU)No 813/2013 of 2 August 2013

Air Source Heat Pumps

Space Heating Test Standard: EN14825

DHW Test Standard: EN16147

Grant Engineering (Ireland) ULC
Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

t: +353 (0)57 91 20089 f: +353 (0)57 91 21060
e: info@grantengineering.ie w: www.grantengineering.ie



Model	Outdoor unit:	Aerona HPR290i160
	Indoor unit:	None
Air to Water Heat Pump		Yes
Brine to Water Heat Pump		No
Low Temperature Heat Pump		No
Equipped with Supplementary Heater		Yes
Heat Pump Combination Heater		Yes
Parameters shall be declared for	Medium Temperature Applications (55°C)	
Parameters shall be declared for	Average Climate Conditions	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	14.01	kW	Seasonal space heating energy efficiency	η_s	132	%
Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj			
Tj = -7°C	<i>Pdh</i>	12.40	kW	Tj = -7°C	<i>COPd</i>	1.82	-
Degradation co-efficient (**)	<i>Cdh</i>	0.99	-				
Tj = +2°C	<i>Pdh</i>	7.71	kW	Tj = +2°C	<i>COPd</i>	3.39	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +7°C	<i>Pdh</i>	5.19	kW	Tj = +7°C	<i>COPd</i>	4.73	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +12°C	<i>Pdh</i>	4.63	kW	Tj = +12°C	<i>COPd</i>	6.56	-
Degradation co-efficient (**)	<i>Cdh</i>	0.96	-				
Tj = bivalent temperature	<i>Pdh</i>	12.40	kW	Tj = bivalent temperature	<i>COPd</i>	1.82	-
Tj = operation limit temperature	<i>Pdh</i>	11.79	kW	Tj = operation limit temperature	<i>COPd</i>	1.90	-
Tj = -15°C (if TOL < -20°C)	<i>Pdh</i>	-	kW	Tj = -15°C (if TOL < -20°C)	<i>COPd</i>	-	-
Bivalent temperature	<i>Tbiv</i>	-7	°C	Operation limit temperature	<i>TOL</i>	-10	°C
				Heating water operating limit temperature	<i>WTOL</i>	75	°C

Power consumption in modes other than active mode				Supplementary Heater			
Off Mode	<i>P_{OFF}</i>	0.009	kW	Rate heat output	<i>P_{sup}</i>	3.00	kW
Thermostat-off mode	<i>P_{TO}</i>	0.03	kW				
Standby mode	<i>P_{SB}</i>	0.009	kW	Type of energy input	Electrical		
Crankcase heater mode	<i>P_{CK}</i>	0.0027	kW				

Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m ³ /h
Sound power level indoors/outdoors	<i>L_{WA}</i>	32/53	dB(A)				
Annual Energy consumption	<i>Q_{HE}</i>	8559	kWh				

For heat pump combination heater				Water heating energy efficiency			
Declared load profile				Reference Hot Water Temperature	θ'_{WH}		°C
Daily electricity consumption	<i>Q_{elec}</i>		kWh	Actual Volume of cylinder under test			Litres
Annual electricity consumption	<i>AEC</i>		kWh/a	Standby Cylinder Heat Loss			kWh

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Model	Outdoor unit:	Aerona HPR290i160
	Indoor unit:	None
Air to Water Heat Pump		Yes
Brine to Water Heat Pump		No
Low Temperature Heat Pump		No
Equipped with Supplementary Heater		Yes
Heat Pump Combination Heater		Yes
Parameters shall be declared for	Low Temperature Applications (35°C)	
Parameters shall be declared for	Average Climate Conditions	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	14.8	kW	Seasonal space heating energy efficiency	η_s	181	%
Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj			
Tj = -7°C	<i>Pdh</i>	13.1	kW	Tj = -7°C	<i>COPd</i>	2.67	-
Degradation co-efficient (**)	<i>Cdh</i>	0.99	-				
Tj = +2°C	<i>Pdh</i>	8.79	kW	Tj = +2°C	<i>COPd</i>	4.72	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +7°C	<i>Pdh</i>	5.79	kW	Tj = +7°C	<i>COPd</i>	6.21	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +12°C	<i>Pdh</i>	4.22	kW	Tj = +12°C	<i>COPd</i>	7.82	-
Degradation co-efficient (**)	<i>Cdh</i>	0.94	-				
Tj = bivalent temperature	<i>Pdh</i>	13.1	kW	Tj = bivalent temperature	<i>COPd</i>	2.67	-
Tj = operation limit temperature	<i>Pdh</i>	12.8	kW	Tj = operation limit temperature	<i>COPd</i>	2.2	-
Tj = -15°C (if TOL < -20°C)	<i>Pdh</i>	-	kW	Tj = -15°C (if TOL < -20°C)	<i>COPd</i>	-	-
Bivalent temperature	<i>Tbiv</i>	-7	°C	Operation limit temperature	<i>TOL</i>	-10	°C
				Heating water operating limit temperature	<i>WTOL</i>	75	°C

Power consumption in modes other than active mode				Supplementary Heater			
Off Mode	<i>P_{OFF}</i>	0.009	kW	Rate heat output	<i>P_{sup}</i>	3.00	kW
Thermostat-off mode	<i>P_{TO}</i>	0.030	kW				
Standby mode	<i>P_{SB}</i>	0.009	kW	Type of energy input	Electrical		
Crankcase heater mode	<i>P_{CK}</i>	0.019	kW				

Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m³/h
Sound power level indoors/outdoors	<i>L_{WA}</i>	32/53	dB(A)				
Annual Energy consumption	<i>Q_{HE}</i>	6656	kWh				

For heat pump combination heater				Water heating energy efficiency			
Declared load profile		NA		<i>η_{wh}</i>			%
Daily electricity consumption	<i>Q_{elec}</i>		kWh				
Annual electricity consumption	<i>AEC</i>		kWh				

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Model	Outdoor unit:	Aerona HPR290i160
	Indoor unit:	None
Air to Water Heat Pump		Yes
Brine to Water Heat Pump		No
Low Temperature Heat Pump		No
Equipped with Supplementary Heater		Yes
Heat Pump Combination Heater		Yes
Parameters shall be declared for	Medium Temperature Applications (55°C)	
Parameters shall be declared for	Colder Climate Conditions	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	13.41	kW	Seasonal space heating energy efficiency	η_s	121	%
Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj			
Tj = -7°C	<i>Pdh</i>	9.70	kW	Tj = -7°C	<i>COPd</i>	2.48	-
Degradation co-efficient (**)	<i>Cdh</i>	0.99	-				
Tj = +2°C	<i>Pdh</i>	6.22	kW	Tj = +2°C	<i>COPd</i>	4.04	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +7°C	<i>Pdh</i>	3.81	kW	Tj = +7°C	<i>COPd</i>	5.24	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +12°C	<i>Pdh</i>	4.29	kW	Tj = +12°C	<i>COPd</i>	7.53	-
Degradation co-efficient (**)	<i>Cdh</i>	0.94	-				
Tj = bivalent temperature	<i>Pdh</i>	11.3	kW	Tj = bivalent temperature	<i>COPd</i>	1.93	-
Tj = operation limit temperature	<i>Pdh</i>	10.1	kW	Tj = operation limit temperature	<i>COPd</i>	1.44	-
Tj = -15°C (if TOL < -20°C)	<i>Pdh</i>	-	kW	Tj = -15°C (if TOL < -20°C)	<i>COPd</i>	-	-
Bivalent temperature	<i>Tbiv</i>	-15	°C	Operation limit temperature	<i>TOL</i>	-22	°C
				Heating water operating limit temperature	<i>WTOL</i>	60	°C
Power consumption in modes other than active mode				Supplementary Heater			
Off Mode	<i>P_{OFF}</i>	0.009	kW	Rate heat output	<i>P_{sup}</i>	3.00	kW
Thermostat-off mode	<i>P_{TO}</i>	0.030	kW				
Standby mode	<i>P_{SB}</i>	0.009	kW	Type of energy input	Electrical		
Crankcase heater mode	<i>P_{CK}</i>	0.019	kW				
Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m³/h
Sound power level indoors/outdoors	<i>L_{WA}</i>	32/53	dB				
Annual Energy consumption	<i>Q_{HE}</i>	11307	kWh				
For heat pump combination heater				Water heating energy efficiency			
Declared load profile		NA			<i>η_{wh}</i>		%
Daily electricity consumption	<i>Q_{elec}</i>		kWh				
Annual electricity consumption	<i>AEC</i>		kWh				

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



Model	Outdoor unit:	Aerona HPR290i160
	Indoor unit:	None
Air to Water Heat Pump		Yes
Brine to Water Heat Pump		No
Low Temperature Heat Pump		No
Equipped with Supplementary Heater		Yes
Heat Pump Combination Heater		Yes
Parameters shall be declared for	Medium Temperature Applications (55°C)	
Parameters shall be declared for	Warmer Climate Conditions	

Item	Symbol	Value	Unit	Item	Symbol	Value	Unit
Rated Heat Output (*)	Prated	16.4	kW	Seasonal space heating energy efficiency	η_s	168	%
Declared capacity for heating for part load at indoor Temperature 20°C and outdoor temperature Tj				Declared coefficient of performance or primary energy ratio for part load at indoor temperature 20°C and outdoor temperature Tj			
Tj = -7°C	<i>Pdh</i>	-	kW	Tj = -7°C	<i>COPd</i>		-
Degradation co-efficient (**)	<i>Cdh</i>	-	-				
Tj = +2°C	<i>Pdh</i>	13.40	kW	Tj = +2°C	<i>COPd</i>	2.04	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +7°C	<i>Pdh</i>	10.62	kW	Tj = +7°C	<i>COPd</i>	3.81	-
Degradation co-efficient (**)	<i>Cdh</i>	0.97	-				
Tj = +12°C	<i>Pdh</i>	4.80	kW	Tj = +12°C	<i>COPd</i>	6.16	-
Degradation co-efficient (**)	<i>Cdh</i>	0.96	-				
Tj = bivalent temperature	<i>Pdh</i>	10.60	kW	Tj = bivalent temperature	<i>COPd</i>	3.81	-
Tj = operation limit temperature	<i>Pdh</i>	13.4	kW	Tj = operation limit temperature	<i>COPd</i>	2.04	-
Tj = -15°C (if TOL < -20°C)	<i>Pdh</i>	-	kW	Tj = -15°C (if TOL < -20°C)	<i>COPd</i>	-	-
Bivalent temperature	<i>Tbiv</i>	7	°C	Operation limit temperature	<i>TOL</i>	2	°C
				Heating water operating limit temperature	<i>WTOL</i>	75	°C

Power consumption in modes other than active mode				Supplementary Heater			
Off Mode	<i>P_{OFF}</i>	0.009	kW	Rate heat output	<i>P_{sup}</i>	3.00	kW
Thermostat-off mode	<i>P_{TO}</i>	0.03	kW				
Standby mode	<i>P_{SB}</i>	0.009	kW	Type of energy input	Electrical		
Crankcase heater mode	<i>P_{CK}</i>	0.0027	kW				

Other items							
Capacity control	Variable			Rated airflow rate, outdoors	-	4050	m³/h
Sound power level indoors/outdoors	<i>L_{WA}</i>	32/53	dB(A)				
Annual Energy consumption	<i>Q_{HE}</i>	5272	kWh				

For heat pump combination heater				Water heating energy efficiency			
Declared load profile				Reference Hot Water Temperature	θ'_{WH}		°C
Daily electricity consumption	<i>Q_{elec}</i>		kWh	Actual Volume of cylinder under test			Litres
Annual electricity consumption	<i>AEC</i>		kWh/a	Standby Cylinder Heat Loss			kWh

Contact Details:

Grant Engineering (Ireland) ULC, Barrack Street, Crinkle, Birr, Co. Offaly, R42 D788, Ireland.

(*) For heat pumps space heaters and heat pump combination heaters, the rated heat output Prated is equal to the design load for heating Pdesignh, and the rated heat output of a supplementary heater Psup is equal to the supplementary capacity for heating sup(Tj).

(**) If Cdh is not determined by measurement then the default degradation coefficient is Cdh = 0.9.



End of Life Information – Air Source Heat Pumps

General

Grant air source heat pumps incorporate components manufactured from a variety of different materials. However, most of these materials cannot be recycled as they are contaminated by the refrigerant and oil used in the heat pump.

Disassembly

This product may only be disassembled by a suitably qualified (F-gas) refrigeration engineer. Under no circumstances should the refrigerant be released into the atmosphere.

Recycling

In order for the heat pump to be recycled or disposed of it must be taken to a suitably licensed waste facility. You will need to contact a qualified refrigeration engineer to do this for you.

Disposal

The refrigerant will be removed and returned to the refrigerant manufacturer for recycling or disposal.

The complete heat pump unit, including the compressor and the oil contained within it, must be disposed of at a licensed waste facility, as it remains contaminated by the refrigerant.

Authorized by:

